

2016 Water Quality Report for Treetops North

This report covers the drinking water quality for Treetops North, located near Gaylord, Michigan, for the calendar year 2016. This information is a snapshot of the quality of the water that we provided to you in 2016. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your water comes from two (2) groundwater wells located on Fazio Drive. A small well (6" diameter) produces 180 gpm and a larger well (16" diameter) produces 1,000 gpm of high quality water. These wells require very little additional treatment. Chlorine is added to disinfect the water to ensure it is safe to drink.

The State of Michigan performed an assessment of our source water in 2004 to determine the susceptibility or relative potential of contamination. The susceptibility rating is a six-tiered scale from "very low" to "very high", based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility to contamination of our source water is ranked as "Low".

A copy of the full assessment report can be obtained at the Treetops Resort office at 3962 Wilkinson Road or at Wade-Trim Operations Services, Inc; PO Box 618; Gaylord, Michigan 49734-0618. Telephone – (989) 732-3584 or via email at pcorkins@wadetrim.com.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

- Contaminants that may be present in source water include:

- * **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.


- * **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

- * **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.

- * **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

- * **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.



The table below lists all the drinking water contaminants that we detected during the 2016 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2016. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity); **RAA:** Running Annual Average.
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Samples Collected at the Wellhouse:

Regulated Chemical Contaminants	MCL	MCLG	Our Water	Sample Date	Violation Yes / No	Typical Source of Contaminants
Fluoride (ppm)	4	4	0.14	2016	No	Erosion of natural deposits

Unregulated Chemical Contaminants ¹	Our Water	Sample Date	Violation Yes / No	Typical Source of Contaminants
Chloride (ppm)	5.0	2016	N/A	Erosion of natural deposits
Sulfate (ppm)	23	2016	N/A	Erosion of natural deposits

¹ Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Samples Collected in the Distribution System:

Contaminants Subject to an Action Level	Action Level	Our Water	Sample Date if not in 2013	Number of Samples Above AL	Typical Source of Contaminants
Lead (ppb) ²	AL = 15	1.2	2014	0	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppb) ²	AL = 1300	36	2014	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

² 90 percent of the samples collected were at or below this level.

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Treetops North water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Disinfection Byproducts	MCLG	MCL	Our water	Range of detections	Sample date	Violation Yes/No	Typical Source of Contaminant
Free Chlorine Residual (ppm) ³	MRDL = 4.0 MRDLG = 4		RAA= 0.48	0.40 – 0.48	Monthly 2016	No	Water additive used to control microbes

³ The MRDL and MRDLG are effective January 1, 2004. Compliance is based on an annual average.

Monitoring and Reporting Requirements: The State and EPA require us to test our water on a regular basis to ensure its safety. We did not meet all the monitoring requirements for 2016. Total Trihalomethanes and Haloacetic Acids were not sampled within the required sampling period. Samples will be collected in August 2016 to comply requirements. We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the Treetops Resort office at 3962 Wilkinson Road Gaylord, MI 49735 or at Wade Trim Operations Services, Inc; 4241 UIS Old 27 South, Suite 1; PO Box 618; Gaylord, Michigan 49734-0618. This report will be delivered to you via email and posted at the Treetops Resort office.

We invite public participation in decisions that affect drinking water quality. For more information about your water, or the contents of this report, contact Phillip Corkins at (989) 732-3584 or via e-mail at pcorkins@wadetrim.com. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.